

**Resolution by the Board of Directors
Sun Vista/Sunlight Beach Homeowners Association
April 25, 2015**

Resolution 15-05-25-001

Whereas:

It is the responsibility of Sun Vista/Sunlight Beach Homeowners Association (hereinafter referred to as the Association) to provide water to the customer that meets State and Federal water quality standards;

And that EPA requirements have reduced the allowable level of arsenic in drinking water to no more than 10 parts per billion (40 CFR 141.62(b)(16));

And that exposure to arsenic carries serious health risks, especially for young children and the elderly;

And that our water in our two wells (Well 1, Well 2) contains arsenic in levels that when drawn from the well can exceed the limits imposed by the EPA;

And that the existing filtration system of the Association cannot reduce the arsenic contained in water drawn from Well 2 such that it complies with (40 CFR 141.62(b)(16));

And that peak consumption periods of the Association may soon exceed the capacity of Well 1, and existing reservoirs, to support uninterrupted service to property owners without pumping water from Well 2;

Now be it **Resolved:** That the Association assess all property owners \$45.00 quarterly, beginning July 1, 2015 through December 31, 2020 for the purpose of upgrading the filtration system to meet Federal and State water purity requirements for all wells, whether pumped together or individually, to provide water to the Association.

Date: _____

Signatures: _____

